

KERALA STATE POLLUTION CONTROL BOARD

കേരള സംസ്ഥാന മലിനീകരണ നിയന്ത്രണ ബോർഡ്



DISTRICT OFFICE, THIRUVANANTHAPURAM
ജില്ലാ ഓഫീസ്, തിരുവനന്തപുരം

T. C. 12/96 (4,5), PLAMOODU JN., PATTOM P.O, THIRUVANANTHAPURAM - 695 004

ടി.സി. 12/96 (4,5), പ്ലാമൂട് ജംഷൻ, പട്ടം പി.ഒ, തിരുവനന്തപുരം - 695 004



ANALYSIS REPORT

No: 202868

22/12/2025

Source		STP Muttathara, Thiruvananthapuram		
Sample Received From		NAMP Operator	Date of sample collection	02/12/2025
Date of Receipt		02/12/2025	Sample ID	E13
Sl. No.	Parameter	Unit	Value	Permissible Limit
1	pH	-	7.0	6.5 - 9.0
2	Total Suspended Solids	mg/L	40	< 50
3	BOD (3 days @ 27°C)	mg/L	9.0	20
4	COD	mg/L	40	-
5	Oil & Grease	mg/L	BDL	-
6	Fecal Coliform	MPN/100ml	Nil	<1000
Remarks: BDL-Below Detection Level				
Verified by				
AISWARYA RAJ V.R.				
Assistant Scientist Scientist-in-Charge of Analysis				
		HIMA S.H.		
		Assistant Environmental Scientist		

KERALA STATE POLLUTION CONTROL BOARD

കേരള സംസ്ഥാന മലിനീകരണ നിയന്ത്രണ ബോർഡ്



DISTRICT OFFICE, THIRUVANANTHAPURAM
 ജില്ലാ ഓഫീസ്, തിരുവനന്തപുരം

T. C. 12/96 (4,5), PLAMOODU JN., PATTOM P.O., THIRUVANANTHAPURAM - 695 004

ടി.സി. 12/96 (4,5), പ്ലാമൂട് ജംഗ്ഷൻ, പട്ടം പി.ഒ, തിരുവനന്തപുരം - 695 004




ANALYSIS REPORT

No: 202867

22/12/2025

Source		CETP KINFRA		
Sample Received From		NAMP Operator	Date of sample collection	04/12/2025
Date of Receipt		04/12/2025	Sample ID	E2
Sl. No	Parameter	Unit	Value	Permissible Limit
				On land for irrigation
1	pH	-	7.1	6.0-9.0
2	Total Suspended Solids	mg/L	3.0	100
3	Total Dissolved Solids	mg/L	702	2100
4	BOD (3 days @ 27° C)	mg/L	2.4	100
5	COD	mg/L	40	250
6	Oil & Grease	mg/L	BDL	10
7	Ammoniacal Nitrogen	mg/L	8.3	NS
8	Nitrate Nitrogen	mg/L	13.3	NS
9	Total Kjeldahal Nitrogen	mg/L	30.1	NS
10	Phosphates	mg/L	0.0321	NS
11	Chlorides	mg/L	324	1000
12	Sulphates	mg/L	1.2278	1000
13	Fluoride	mg/L	0.8	2
14	Total Residual Chlorine	mg/L	2	1
15	Phenolic Compounds	mg/L	BDL	1
16	Sulphides	mg/L	BDL	2
17	Cyanide	mg/L	BDL	NS

Remarks: BDL-Below Detection Level , NS -Not Specified

Verified by 
AISWARYA RAJ V.R.
 Assistant Scientist
 Scientist-in-Charge of Analysis


HIMA S.H.
 Assistant Environmental Scientist

KERALA STATE POLLUTION CONTROL BOARD

കേരള സംസ്ഥാന മലിനീകരണ നിയന്ത്രണ ബോർഡ്

DISTRICT OFFICE, THIRUVANANTHAPURAM
ജില്ലാ ഓഫീസ്, തിരുവനന്തപുരം

T. C. 12/96 (4,5), PLAMOODU JN., PATTOM P.O, THIRUVANANTHAPURAM - 695 004

ടി.സി. 12/96 (4,5), പ്ലാമൂട് ജംഷൻ, പട്ടം പി.ഒ, തിരുവനന്തപുരം - 695 004


**LIFE**
Lifestyle for
Environment**ANALYSIS REPORT**


No: 202866

22/12/2025

Source		Medical College Hospital, Thiruvananthapuram.		
Sample Received From	NAMP Operator	Date of sample collection	04/12/2025	
Date of Receipt	04/12/2025	Sample ID	E1	
Sl. No.	Parameter	Unit	Value	Permissible Limit
1	pH	-	3.4	6.5 - 8.5
2	Total Suspended Solids	mg/L	9.0	10
3	BOD (3 days @ 27°C)	mg/L	0.6	3
4	Oil & Grease	mg/L	0.7	1
5	Bio-assay Test	-	100% fish died within 1 hour.	90% survival of fish after 96 hours in 100% effluent prior to disinfection.
6	COD	mg/L	44	-
7	Total Coliform	cfu/100ml	Nil	-
8	Fecal Coliform	cfu/100ml	Nil	-

Verified by


AISWARYA RAJ V.R.
Assistant Scientist
Scientist-in-Charge of Analysis


HIMA S.H.
Assistant Environmental Scientist



ജില്ലാ ഓഫീസ്, ആലപ്പുഴ
കേരള സംസ്ഥാന മലിനീകരണ നിയന്ത്രണ ബോർഡ്
KERALA STATE POLLUTION CONTROL BOARD
DISTRICT OFFICE, ALAPPUZHA



എസ്.എൻ.ടി.സി.സംസ്ഥാനം, ന്യൂ ചാത്തനാട്, ഹെഡ് പോസ്റ്റ് ഓഫീസ്, ആലപ്പുഴ - 688001
 SNV Sadhanam, New Chathanad, Head Post Office, Alappuzha - 688001
 E-mail: alpy.pcb@gmail.com Telephone: 0477-2235384 web: www.keralapcb.nic.in

ഓൺലൈനിൽ അപേക്ഷകൾ സമർപ്പിക്കുന്നതിന് keralapcbonline.com എന്ന വെബ്സൈറ്റ് ഉപയോഗിക്കുക.

ANALYSIS REPORT (WATER/EFFLUENT/SOLID WASTE)		No. 463	Date: 31/12/2025
Source	Sea food park ,Aroor, Alappuzha		
Date of sample Collection	02/12/2025	Sample received from	EE
Ref.No.		Period of analysis	
Date of Receipt	02/12/2025		
Scientist-in-charge of analysis		ASSISTANT SCIENTIST	

Sl.no	Parameter	Unit	Value			
			Sample No.			
			SFP			Limit*
1	pH	-	7.5			6.5-8.5
2	Suspended Solids	mg/L	5			100
3	BOD	mg/L	11.62			30
4	Oil & grease	mg/L	BDL			10
Details of samples:						
Remarks:						

*- Limit as per the circular of treated effluent standards for sewage treatment plants

Verified
 31/12/2025

AJIS MARIA
 ASSISTANT SCIENTIST

ജില്ലാ ഓഫീസ്, ആലപ്പുഴ
കേരളസംസ്ഥാന മലിനീകരണ നിയന്ത്രണ ബോർഡ്
KERALA STATE POLLUTION CONTROL BOARD
DISTRICT OFFICE, ALAPPUZHA

എസ്.എൻ.ടി.സദനം, ന്യൂ ചാത്തനാട്, ഹെഡ് പോസ്റ്റ് ഓഫീസ്, ആലപ്പുഴ - 688001
 SNV Sadhanam, New Chathanad, Head Post Office, Alappuzha - 688001



E-mail: alpy.pcb@gmail.com Telephone : 0477 - 2965384 web: www.kspcb.kerala.gov.in ഓൺലൈനിൽ
 അപേക്ഷകൾ സമർപ്പിക്കുന്നതിന് <https://keralapcbonline.com> എന്ന വെബ്സൈറ്റ് ഉപയോഗിക്കുക.

“ഭരണഭാഷ- മാതൃഭാഷ”

ANALYSIS REPORT (WATER/EFFLUENT/SOLID WASTE)		No. 459	Date: 24/12/2025
Source	KSIDC Mega food park, pallipuram, cherthala		
Date of sample Collection	11/12/2025	Sample received from	AE4
Ref.No.		Period of analysis	
Date of Receipt	11/12/2025		
Scientist-in-charge of analysis		ASSISTANT SCIENTIST	

Sl. n o.	Parameter	Unit	Value			
			Sample No.			Limit*
			MFP			
1	pH	-	7.7			6.5 – 8.5
2	Suspended Solids	mg/L	21.2			100
3	BOD	mg/L	30.24			30
4	Oil & Grease	mg/L	BDL			10
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						

Details of samples

Remarks: BOD value exceeded the limit

*- Limit as per the consent

Verified
 29/12/2025
AJIS MARIA
 ASSISTANT SCIENTIST

KERALA STATE POLLUTION CONTROL BOARD

കേരളസംസ്ഥാന മലിനീകരണ നിയന്ത്രണ ബോർഡ്



DISTRICT OFFICE (ERNAKULAM-II), PERUMBAVOOR

ജില്ലാകാര്യാലയം (എറണാകുളം-2) പെരുമ്പാവൂർ

PMC. 20/733, Near Kallumkal Auditorium, Perumbavoor - 683 542
പിഎംസി. 20/733, കല്ലുകൽ ഓഡിറ്റോറിയം സമീപം, പെരുമ്പാവൂർ - 683 542



☎: 0484-2593747

e-mail: pcbdo2ekm@gmail.com

web: www.kspcb.keralagov.in

PCB/PBR/LAB/1/2013


Date: 04.12.2025

ANALYSIS REPORT

Source : SEPTAGE TREATMENT PLANT, BRAHMAPURAM
Sample Point : FILTERED EFFLUENT TANK
Date of sampling : 14.11.2025
Date of receipt : 14.11.2025
Collected by : AS
Analysed by : JSAI & JSA II
Sample ID : PCB/PVR/138/2025-26

Sl. No.	Parameters	Unit	Value	Test Method	KSPCB Limit
1	pH		6.53	APHA, 4500 H ⁺ B 24 th Edition 2023	5.5-9.0
2	BOD	mg/L	3	APHA, 5210 B, 24 th Edition 2023	30
3	COD	mg/L	24	APHA, 5220 B, 24 th Edition 2023	250
4	OIL AND GREASE	mg/L	BDL	APHA, 5520 B, 24 th Edition 2023	10
5	TOTAL SUSPENDED SOLIDS	mg/L	BDL	APHA, 2540-D, 24 th Edition 2023	100
6	PHOSPHATES	mg/L	BDL	APHA-4500 P-E 24 th Edition 2023	5
7	NITRATES	mg/L	1.44	APHA 4500-NO ₃ -E, 24 th Edition 2023	10
8	SULPHATES	mg/L	11.89	APHA, 4500-SO ₄ , 24 th Edition 2023	1000
9	SULPHIDES	mg/L	2.67	APHA-4500-S ²⁻ D 24 th Edition 2023	2
10	AMMONIACAL NITROGEN	mg/L	1.06	APHA, 4500-NH ₃ -F, 24 th Edition 2023	50
11	PHENOLIC COMPOUNDS	mg/L	BDL	APHA, 5530 C, 24 th Edition 2023	1
12	FAECAL COLIFORM	cfu/100mL	35	APHA 9222 D, 24 th Edition 2023	<1000
13	FAECAL STREPTOCOCCI	cfu/100mL	38	APHA 9230 A, 24 th Edition 2023	-

BDL - BELOW DETECTION LIMIT


ASHNA SHAJI
ASSISTANT SCIENTIST



**KERALA STATE POLLUTION CONTROL BOARD
CENTRAL LABORATORY**

**കേരള സംസ്ഥാന മലിനീകരണ നിയന്ത്രണ
ബോർഡ്
കേന്ദ്ര പരീക്ഷണശാല**



TC 8525

TEST REPORT

Analysis Report No.	PCB/CL/1442/2025-26	Date	03.12.2025	Format No.	PCB/CL/CH/F-7
Ref. No.	PCB/EKM/DO-1 Dated 01.11.2025	Date of Collection	31.10.2025		
Received From	Environmental Engineer	Date of Receipt	01.11.2025		
No. of Sample	01	Period of Analysis	03.11.2025 – 29.11.2025		
Source	Elamkulam CSTP.	Scientist-in-charge	Sreeja K.B		
Sample Condition	Fit for analysis	Sample Type	Water Samples		
Sample collected by	The Environmental Engineer, Disrtict Office,Ernakulam	Sample volume & container type	Plastic Can		
Sample preservation	As per APHA/IS:3025 (Part-1)	Type of Test	Chemical		

SAMPLE ID : ECS TP

Sl. No	Parameters	Unit	Value	Test Method	Lowest Detection Limit
1	pH	---	7.41	APHA, 4500-H+B, 24 th Ed., 2023	1
2	Total Suspended Solids	mg/L	16.6	APHA, 2540-D, 24 th Ed., 2023	10 mg/l.
3	Ammonia as Nitrogen	mg/L	2.94	APHA-4500 NH3-C, 24 th Ed., 2023	0.02 mg/L
4	Free Ammonia	mg/L	0.053	GEMS OPERATIONAL GUIDE WHO	0.003 mg/L
5	BOD	mg/L	1.2	IS 3025 Part(44): 2023	1 mg/l.
6	COD	mg/L	24	APHA, 5220-B, 24 th Ed., 2023	4 mg/L
7	Oil & grease	mg/L	BDL	APH, 5520-B, 24 th Ed., 2023	5 mg/l.
8	Nitrite as Nitrogen	mg/L	0.295	APHA, 4500-NO2-B, 24 th Ed., 2023	0.02 mg/l.
9	Nitrates as Nitrogen	mg/L	4.515	APHA, 4500-NO3, 24 th Ed., 2023	0.01 mg/l.

GANDHI NAGAR, KOCHI - 682 020 ഗാന്ധിനഗർ, കൊച്ചി - 682 020
Ph: 0484 220 7781, EPABX: 0484 220 7783 - 86, Fax: 0484 - 220 7781, Mob: 9447975741
E Mail: kspcbclm@gmail.com, kspcbnwmp@gmail.com Web: www.keralapcb.nic.in
Certified for OHSMS (ISO 45001:2018)



0000

10	Total Kjeldahl Nitrogen	mg/L	5.88	APHA, 4500-N org B, 24 th Ed. 2023	0.2 mg/L
11	Total Nitrogen	mg/L	10.69	APHA, 4500-NO2-B, 24 th Ed., 2023 APHA, 4500-NO3, 24 th Ed., 2023 APHA, 4500-N org B, 24 th Ed. 2023	-----

--End of Report--

Checked By

Sowmya
03/12/2025

Sowmya T M
Assistant Scientist

Authorised By

Sreeja

SREEJA. K.B
Senior Environmental Scientist & Govt. Analyst

Note: The test results relate only to the sample submitted for analysis and it shouldn't be reproduced except in full without the written permission of the authorised signatory of the lab.



**KERALA STATE POLLUTION CONTROL BOARD
CENTRAL LABORATORY**

കേരള സംസ്ഥാന മലിനീകരണ നിയന്ത്രണ ബോർഡ്
കേന്ദ്ര പരീക്ഷണശാല

An Environmental Laboratory recognised under E(P)A 1986



TC 8525

TEST REPORT

Analysis Report No.	PCB/CL/1442/2025-26	Date	07.11.2025	Format No.	PCB/CL/CH/F-7
Ref. No.	PCB/EKM/DO-1 Dated 01.11.2025	Date of Collection	31.10.2025		
Received From	District Office, Ernakulam	Date of Receipt	01.11.2025		
No. of Sample	01	Period of Analysis	04.11.2025 -06.11.2025		
Source	Elamkulam CSTP-Out to drain	Scientist-in-charge	P. Geetha		
Sample Condition	Fit for analysis	Sample Type	Waste Water		
Sample collected by	The Environmental Engineer, District Office, Ernakulam	Sample volume & container type	Sterilized DO Bottle		
Sample preservation	As per APHA/IS:3025 (Part-1)	Type of test	MICROBIOLOGY		

Sample ID: Bio -905

Sl. No	Parameters	Unit	Value	Test Method	Detection Limit
1	Faecal Coliform	cfu /100 ml	1240	APHA 9222 D, 24 th Ed. 2023	1cfu/100 ml

--End of Report--

Checked by

Anisha M N
07/11/25

Anisha M N
Assistant Scientist

P. Geetha
07/11/25

Authorised By

P. GEETHA
Chief Environmental Scientist & Govt. Analyst

Note: The test results relate only to the sample submitted for analysis and it shouldn't be reproduced except in full without the written permission of the authorised signatory of the lab.

GANDHI NAGAR, KOCHI - 682 020 ഗാന്ധിനഗർ കൊച്ചി 682 020

Ph: 0484 220 7781, EPABX: 0484 220 7783 - 86, Fax: 0484 - 220 7781, Mob: 9447975741

E Mail: kspcbclm@gmail.com, kspcbnwmp@gmail.com Web: www.keralapcb.nic.in

Certified for OHSMS (ISO 45001:2018)





KERALA STATE POLLUTION CONTROL BOARD
CENTRAL LABORATORY

കേരള സംസ്ഥാന മലിനീകരണ നിയന്ത്രണ
ബോർഡ്
കേന്ദ്ര പരീക്ഷണശാല



TC 8525

TEST REPORT

Analysis Report No.	PCB/CL/1634/2025-26	Date	23.12.2025	Format No.	PCB/CL/CH/F-7
Ref. No.	PCB/EKM/DO-1 Dated 24.11.2025.	Date of Collection	22.11.2025		
Received From	Environmental Engineer	Date of Receipt	24.11.2025		
No. of Sample	01	Period of Analysis	25.11.2025 – 20.12.2025		
Source	GCDA CSTP at Marine Drive.	Scientist-in-charge	Sreeja K.B		
Sample Condition	Fit for analysis	Sample Type	Waste Water Samples		
Sample collected by	The Environmental Engineer, District Office,Ernakulam	Sample volume & container type	Plastic Can		
Sample preservation	As per APHA/IS:3025 (Part-1)	Type of Test	Chemical		

SAMPLE ID: CSTP M

Sl. No	Parameters	Unit	Value	Test Method	Lowest Detection Limit
1	pH	---	7.05	APHA, 4500-H+B, 24 th Ed., 2023	1
2	Total Suspended Solids	mg/L	63.6	APHA, 2540-D, 24 th Ed., 2023	10 mg/L
3	Phosphates	mg/L	4.7	APHA, 4500-P E, 24 th Ed., 2023	0.01mg/L
4	Ammonia as Nitrogen	mg/L	32.34	APHA-4500 NH3-C, 24 th Ed., 2023	0.02 mg/L
5	BOD	mg/L	36	IS 3025 Part(44): 2023	1 mg/L
6	COD	mg/L	92	APHA, 5220-B, 24 th Ed., 2023	4 mg/L
7	Oil & grease	mg/L	BDL	APH, 5520-B, 24 th Ed., 2023	5 mg/L
8	Nitrite as Nitrogen	mg/L	0.021	APHA, 4500-NO2-B, 24 th Ed., 2023	0.02 mg/L
9	Nitrates as Nitrogen	mg/L	0.540	APHA, 4500-NO3, 24 th Ed., 2023	0.01 mg/L

GANDHI NAGAR, KOCHI - 682 020 ഗാന്ധിനഗർ, കൊച്ചി - 682 020

Ph: 0484 220 7781, EPABX: 0484 220 7783 - 86, Fax: 0484 - 220 7781, Mob: 9447975741
E Mail: kspcbelem@gmail.com, kspcبنwmp@gmail.com Web: www.keralapcb.nic.in
Certified for OHSMS (ISO 45001:2018)



0006

10	Total Kjeldahl Nitrogen	mg/L	37.632	APHA, 4500-N org B, 24 th Ed. 2023	0.2 mg/L
11	Total Nitrogen	mg/L	38.193	APHA, 4500-N org B, 24 th Ed. 2023, APHA, 4500-NO2-B, 24 th Ed., 2023, APHA, 4500-NO3, 24 th Ed., 2023.	-----

--End of Report--

Checked By

Sowmya
23/12/2023

Sowmya T M
Assistant Scientist

Authorised By

Sreeja

SREEJA. K.B
Senior Environmental Scientist & Govt. Analyst

Note: The test results relate only to the sample submitted for analysis and it shouldn't be reproduced except in full without the written permission of the authorised signatory of the lab.



**KERALA STATE POLLUTION CONTROL BOARD
CENTRAL LABORATORY**

കേരള സംസ്ഥാന മലിനീകരണ നിയന്ത്രണ ബോർഡ്
കേന്ദ്ര പരീക്ഷണശാല

An Environmental Laboratory recognised under E(P)A 1986



TC 8525

TEST REPORT

Analysis Report No.	PCB/CL/1634/2025-26	Date	05.12.2025	Format No.	PCB/CL/CH/F-7
Ref. No.	PCB/EKM/DO-1 Dated 24.11.2025	Date of Collection	22.11.2025		
Received From	District Office, Ernakulam	Date of Receipt	24.11.2025		
No. of Sample	01	Period of Analysis	27.11.2025 – 03.12.2025		
Source	GCDA CSTP at Marine drive - Filter Out	Scientist-in-charge	P. Geetha		
Sample Condition	Fit for analysis	Sample Type	Waste Water		
Sample collected by	The Environmental Engineer, District Office, Ernakulam	Sample volume & container type	Sterilized DO Bottle		
Sample preservation	As per APHA/IS:3025 (Part-1)	Type of test	MICROBIOLOGY		

Sample ID: Bio - 64

Sl. No	Parameters	Unit	Value	Test Method	Detection Limit
1	Faecal Coliform	cfu/100 ml	48×10 ³	APHA 9222 D, 24 th Ed. 2023	1cfu/100 ml

--End of Report--

Checked by

Anisha M N
05/12/25

Anisha M N
Assistant Scientist

Authorised By

P. Geetha
05/12/25

P. GEETHA
Chief Environmental Scientist & Govt. Analyst

Note: The test results relate only to the sample submitted for analysis and it shouldn't be reproduced except in full without the written permission of the authorised signatory of the lab.

GANDHI NAGAR, KOCHI - 682 020 ഗാന്ധിനഗർ കൊച്ചി 682 020

Ph: 0484 220 7781, EPABX: 0484 220 7783 - 86, Fax: 0484 - 220 7781, Mob: 9447975741

E Mail: kspcbclek@gmail.com, kspcbnwmp@gmail.com Web: www.keralapcb.nic.in

Certified for OHSMS (ISO 45001:2018)

-1-



0008



കേരള സംസ്ഥാന മലിനീകരണ നിയന്ത്രണ ബോർഡ്

മണ്ണികടം സർക്കാർ, മുത്താം തിരി, പാവട്ടാനി, ഒളുക്കര പി.ഒ., തൃശ്ശൂർ-680655

KERALA STATE POLLUTION CONTROL BOARD

Majestic Square, 3rd Floor, Paravattani, Ollukkara P.O., Thrissur-680655

ANALYSIS REPORT (WATER/EFFLUENT/SOLID WASTE)		No: TAS 1418 Date: 08.05.2025	
Source	General Hospital, Thrissur		
Date of Sample Collection	23.04.2025	EE, THRISSUR	
Ref. No.	PCB/TSR/IC/180/97 Dated 24.04.2025	Period of analysis	24.04.2025-08.05.2025
Date of Receipt	24.04.2025		
Sample Collected by	AEE		
Methods	Standard methods for the examination of Water and Waste Water, APHA AWWA WEF (24 th Edition 2023)		
Scientist – in –charge of analysis	DHANYA O G		

SI No	Parameter	Unit	Value	Acceptable Limit	Method
			GH(Treated waste water after Ultra Filtration)		
1	pH	---	7.8	5.5-9.0	APHA 4500-H+,B
2	Biochemical Oxygen Demand	mg/l	3.0	30	APHA 5210, B
3	Suspended solids	..	0.1	100	APHA 2540, D
4	Oil&Grease	..	0.92	10	APHA 5520, B

Dhanya
08/05/25
Dhanya O.G.
Assistant Scientist

AEE/AS
Dhanya
08/05/25



Telephone No: 0487 - 2374939

E-mail: kspcbtsr@gmail.com

കേരള സംസ്ഥാന മലിനീകരണ നിയന്ത്രണ ബോർഡ്

മജസ്റ്റിക് സ്ക്വയർ, മൂന്നാം നില, പരവട്ടാനി, ഒല്ലൂക്കര പി.ഒ., തൃശ്ശൂർ-680655

KERALA STATE POLLUTION CONTROL BOARD

Majestic Square, 3rd Floor, Paravattani, Ollukkara P.O., Thrissur-680655

ANALYSIS REPORT (WATER/EFFLUENT/SOLID WASTE)		No: TAS 1573 Date:15.01.2026	
Source	General Hospital Thrissur	EE, THRISSUR	
Date of Sample Collection	27.11.2025		
Ref. No.	PCBDTR/502/2025-EE Dated 29.11.2025	Period of analysis	29.11.2025-15.01.2026
Date of Receipt	29.11.2025		
Sample Collected by	NAMP Operator 3 for AE2		
Methods	Standard methods for the examination of Water and Waste Water, APHA AWWA WEF (24 th Edition 2023)		
Scientist – in –charge of analysis	DHANYA O G		

SI No	Parameter	Unit	Value	Tolerance Limit	Method
			DHT (STP Outlet)		
1	pH	---	4.6	6.5-8.5	APHA 4500-H+,B
2	Biochemical Oxygen Demand	mg/l	2.4	< 10	APHA 5210, B
3	Chemical Oxygen Demand	„	12	< 50	APHA-5220, B
4	Suspended solids	„	6.1	< 20	APHA 2540, D
5	Total Nitrogen	„	2.8	< 10	APHA 4500 N, APHA 4500 NO ² B, APHA 4500 NO ³ - B
6	Total Phosphorous	„	BDL	< 1.0	APHA 4500-P
7	Oil &Grease	„	0.37	< 10	APHA 5520, B
8	Faecal Coliforms	CFU/100ml	NIL	< 100	APHA 9222 D



☎: General: 0483- 2733211

e-mail:kspcbmlpm@gmail.com, Fax: 0483 2733211 web: kspcb.kerala.gov.in

KERALA STATE POLLUTION CONTROL BOARD

കേരള സംസ്ഥാന മലിനീകരണ നിയന്ത്രണ ബോർഡ്

District Office Malappuram, Perinthalmanna Road, Up Hill, Malappuram-676505

ജില്ലാ ഓഫീസ് മലപ്പുറം, പെരിന്തൽമണ്ണ റോഡ്, കുന്नुമ്മൽ, മലപ്പുറം -676505



ANALYSIS REPORT- EFFLUENT		REPORT No: E 63/25		Date: 15.05.2025	
Source	STP of Tirur Municipality Fish Market, Tirur, Malappuram-676101	No.of Samples		1	
		Sample ID		PCB-Y-After Filtration	
		Sample volume, Container type		2.5L, Plastic can	
Date of Sample Collection	02.05.2025	Sample type	Effluent water	Type of test	Chemical
Date of Receipt	03.05.2025	Period of Analysis		03.05.2025 to 15.05.2025	
Samples Collected by	District Office, Malappuram	Scientist in-charge		Assistant Scientist	

Serial No.	Parameter	Unit	Value	Test Method
			PCB-Y	
1	pH	-	5.9	APHA 4500-H+ B
2	Biochemical Oxygen Demand (BOD)	mg/l	4.4	IS 3025 Part 44
3	Chemical Oxygen Demand (COD)	mg/l	16	APHA 5220 B
4	Total Suspended Solid (TSS)	mg/l	58	APHA 2540 D
5	Oil and Grease	mg/l	BDL	APHA 5220 B

ASSISTANT SCIENTIST

☎: General: 0483- 2733211

e-mail:kspcbmlpm@gmail.com, Fax: 0483 2733211 web: kspcb.kerala.gov.in

KERALA STATE POLLUTION CONTROL BOARD

കേരള സംസ്ഥാന മലിനീകരണ നിയന്ത്രണ ബോർഡ്

District Office Malappuram, Perinthalmanna Road, Up Hill, Malappuram-676505

ജില്ലാ ഓഫീസ് മലപ്പുറം, പെരിന്തൽമണ്ണ റോഡ്, കുന്നൂമ്മൽ, മലപ്പുറം -676505



ANALYSIS REPORT- EFFLUENT		REPORT No: E 66/25		Date: 23.05.2025	
Source	STP of Tirur Municipality Bus Stand, Tirur, Malappuram-676101	No.of Samples		2	
		Sample ID		PCB-XY-Before Filtration PCB-X- After Filtration	
		Sample volume, Container type		2.5L, Plastic can	
Date of Sample Collection	02.05.2025	Sample type	Effluent water	Type of test	Chemical
Date of Receipt	03.05.2025	Period of Analysis		03.05.2025 to 22.05.2025	
Samples Collected by	District Office, Malappuram	Scientist in-charge		Assistant Scientist	

Serial No.	Parameter	Unit	Value		Test Method
			PCB-XY	PCB-X	
1	pH	-	6.6	6.5	APHA 4500-H+ B
2	Biochemical Oxygen Demand (BOD)	mg/l	260	19	IS 3025 Part 44
3	Chemical Oxygen Demand (COD)	mg/l	880	80	APHA 5220 B
4	Total Suspended Solid (TSS)	mg/l	162	56	APHA 2540 D
5	Oil and Grease	mg/l	BDL	BDL	APHA 5220 B

ASSISTANT SCIENTIST